

DEI Accessories

MTL Lead Kit

Connection" of an "SSD qt"QXR4"normally wugu #6
CY I "insulated leads with compression terminals. Each
røcf "j cu a factory installed compression terminal on
one end with the other lead end left unfinished for cut-
ting to the shortest feasible length during installation.
(The required 5/16" bolts, nuts and washers to attach
the leads to the device are furnished with each decou-
pler.) The standard lengths are 12 inches (300mm) and
36 inches (900mm).

Specify part number MTL-6-12 or MTL-6-36 for a
set of two conductors with 12" or 36" lengths, respec-
tively. For custom lengths, specify MTL-6-"X" and
specify the units for "X." If a terminal is required for
the unfinished end of the lead, contact DEI.

Note: For any model with an AC fault current rat-
ing equal to or greater than 2.0kA or for use with a
Gradient Control Mat, two leads per terminal are
required. Therefore, take care to order the correct
number of leads for the mounting option selected. If
one set of leads is to be connected to a DEI furnished
Gradient Control Mat, then the lead-to-mat connec-
tion will be thermit welded. See DEI information on
Gradient Control Mats for connection details.

