

CERTIFICATE OF COMPLIANCE

Certificate Number E187183
Report Reference E187183-20000329
Issue Date 2020-JUNE-04

Issued to: DAIRYLAND ELECTRICAL INDUSTRIES INC
340 BUSINESS PARK CIR
PO BOX 187
STOUGHTON WI 53589-0187

This certificate confirms that representative samples of Surge Protectors and Isolators for Use on Cathodically Protected Systems for Use in Hazardous Locations
Refer to addendum page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E187183
Report Reference E187183-20000329
Issue Date 2020-JUNE-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Polarization Cell Replacement Units, Overvoltage Protectors,
Isolators and Decouplers for use in Class I, Groups A, B, C and D, Division 2 Hazardous Locations.

All model devices may have a surge current rating of 100 kA maximum.

Polarization Cell Replacement Units:

Models PCR followed by -3.7kA, -5kA, -10kA, -15kA, may be followed by /80A, may be followed by -S, may be followed by either 50, 75, or 100, may be followed by any combination of the following: CC, LA, 4H, CS2, may be followed by three letter suffix for external mounting option.

Models PCR followed by -3.5kA, -9kA, -14kA, may be followed by /80A, may be followed by -S, may be followed by either 50, 75, or 100, may be followed by any combination of the following: CC, LA, 4H, CS2, may be followed by three letter suffix for external mounting option.

Models PCR followed by -2.6kA, -6.8kA or 10.5kA, may be followed by /44A, may be followed by -S, may be followed by either 50, 75, or 100, may be followed by any combination of the following: CC, LA, 4H, CS2, may be followed by three letter suffix for external mounting option.

Overvoltage Protectors:


Models OVP2, followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 1.2, may be followed by 75, may be followed by -R.

Models OVP2, followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 2.0, 3.7, or 5.0, may be followed by 100, may be followed by -R.

Decouplers & Isolators:

Models SSD, GI, GD, GCMD, GMD, PCD or TSD followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 1.2, may be followed by 75, may be followed by -R.

Models SSD, GI, GD, GCMD, GMD, PCD or TSD followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 2.0, 3.7, or 5.0, may be followed by 100, may be followed by -R.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

