

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No .:	IECEx UL 14.0021X	Page 1 of 4	Certificate history: Issue 2 (2020-06-30)
Status:	Current	Issue No: 3	Issue 2 (2020-00-00) Issue 1 (2016-04-07) Issue 0 (2014-03-07)
Date of Issue:	2021-06-29		13500 0 (2014-03-07)
Applicant:	Dairyland Electrical Industries Inc. 340 Business Park Circle PO Box 187 Stoughton, WI 53589 United States of America		
Equipment:	Overvoltage Protectors, Model series OVP2. Decouplers and Isolators, Model series SSD, GI, GD, GCMD, GMD, PCD and TSD		
Optional accessory:			
Type of Protection:	Increased Safety "ec"		
Marking:	Ex ec IIC T4 Gc		
	-45°C ≤Ta≤ +65°C		
Approved for issue o Certification Body:	n behalf of the IECEx	Lucy Frieders	
Position:		Staff Engineer	
Signature:			
(for printed version)			
Date:			
2. This certificate is not	cchedule may only be reproduced in full. transferable and remains the property of the issuing b enticity of this certificate may be verified by visiting ww	ody. w.iecex.com or use of this QR Code.	
Certificate issued	l by:		
UL LLC 333 Pfingsten R Northbrook IL 6 United States of	0062-2096		Щ)



Certificate No.: Date of issue:	IECEx UL 14.0021X 2021-06-29	Page 2 of 4 Issue No: 3
Manufacturer:	Dairyland Electrical Industries Inc. 340 Business Park Circle PO Box 187 Stoughton, WI 53589 United States of America	
Additional manufacturing locations:	Dairyland Electrical Industries Inc. 110 Memorial Drive Pound, WI 54161 United States of America	

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-7:2017 Edition:5.1	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

US/UL/ExTR14.0031/00 US/UL/ExTR14.0031/03 US/UL/ExTR14.0031/01

US/UL/ExTR14.0031/02

Quality Assessment Report:

US/UL/QAR14.0006/04



Certificate No .:

IECEx UL 14.0021X

Date of issue:

Page 3 of 4

2021-06-29

Issue No: 3

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

These devices are intended to be used to provide AC grounding and DC blocking for cathodic protection of underground pipelines and similar installation in explosive atmospheres.

Please see Annex for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- Plastic enclosures are to be cleaned or wiped with a damp cloth.
- During installation the device should be handled and mounted in a location so that direct impact is minimized.



Certificate No.: IECEx UL 14.0021X

Date of issue:

2021-06-29

Page 4 of 4

Issue No: 3

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1: The instructions and enclosure material were revised.

Issue 2: Standard update for 60079-0. Changes to the internal construction and components. Alternate securement method for the nameplate.

Issue 3: The IEC 60079-15 standard is updated to IEC 60079-7, 5.1 Ed. Marking string on the label and instructions were revised to Ex ec IIC T4 Gc. Minor Revisions made to the construction.

Annex:

Annex to IECEx UL 14.0021X Issue 3.pdf



Certificate No .:

IECEx UL 14.0021X

Issue No.: 3 Page 1 of 3

TYPE DESIGNATION AND PARAMETERS RELATING TO THE SAFETY

Nomenclature:

Overvoltage Protectors:

Models OVP2, followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 1.2, may be followed by 75. Models OVP2, followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 2.0, 3.7, or 5.0, may be followed by 100.

 $\frac{\mathsf{OVP2}}{\mathsf{I}} \quad \frac{2/1}{\mathsf{II}} \quad \frac{2}{\mathsf{III}} \quad \frac{100}{\mathsf{IV}}$

I. Basic Model Series and device name OVP2 – Overvoltage protector

II. Designates Peak Blocking Voltage (Negative Peak/Positive Peak)

1/1	-	-1V/+1V
1.5/1.5	-	-1.5V/+1.5V
2/1	-	-2V/+1V
2/2	-	-2V/+2V
3/1	-	-3V/+1V
4/1	-	-4V/+1V

III. Designates AC Current Rating (rms)

- 1.2 1.2 kiloamperes
- 2.0 2.0 kiloamperes
- 3.7 3.7 kiloamperes
- 5.0 5.0 kiloamperes

IV. Optional - Surge Current Rating 75 – 75 kA. 100 – 100 kA.



Certificate No .:

IECEx UL 14.0021X

Issue No.: 3

Page 2 of 3

Decouplers & Isolators:

Models SSD, GI, GD, GCMD, GMD, PCD or TSD followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by 1.2, may be followed by 75.

Models SSD, GI, GD, GCMD, GMD, PCD or TSD followed by 1/1, 1.5/1.5, 2/1, 2/2, 3/1, 4/1, followed by, 2.0, 3.7, or 5.0, may be followed by 100.

All decouplers and isolators are identical, except for the prefix number (SSD, GI, GD, GCMD, GMD, PCD or TSD). Model OVP2 devices are not provided with a capacitor. Model PCR, SSD, GI, GD, GCMD, GMD, PCD and TSD devices are provided with a capacitor.

SSD	2/1	1.2	100
	11	111	IV

I. Basic Model Series

SSD – Solid state decoupler GI – Galvanic isolator GD – Galvanic decoupler GCMD – Gradient control mat decoupler GMD – Ground mat decoupler PCD – Pipeline casing decoupler TSD –Test station decoupler

II. Designates Peak Blocking Voltage (Negative Peak/Positive Peak)

1/1	-	-1V/+1V
1.5/1.5	-	-1.5V/+1.5V
2/1	-	-2V/+1V
2/2	-	-2V/+2V
3/1	-	-3V/+1V
4/1	-	-4V/+1V

III. Designates AC Current Rating (rms)

- 1.2 1.2 kiloamperes
- 2.0 2.0 kiloamperes
- 3.7 3.7 kiloamperes
- 5.0 5.0 kiloamperes
- VI. Optional Surge Current Rating 75 – 75 kA

Electrical data

All model devices may have a lightning surge current rating of 100 kA (8 x 20µs waveform).



Certificate No .:

IECEx UL 14.0021X

Issue No.: 3 Page 3 of 3

MARKING

Marking has to be readable and indelible; it has to include the following indications:

